

**Table A**

**Road Width for Parking**

---

<b>Road Width</b>	<b>Parking</b>
<b>24 feet</b>	<b>No Parking on Street, two-way traffic</b>
<b>30 feet</b>	<b>Parking one side of street</b>
<b>36 feet</b>	<b>Parking two sides of street</b>

---

**Table B**

**Distribution System Piping**

---

<b>Size of Main (inside diameter)</b>	<b>Maximum No. of Mobile Homes That May Be Serviced</b>	<b>Maximum Length of Main Installed (in feet)</b>
<b>2"</b>	<b>20</b>	<b>600</b>
<b>3"</b>	<b>60</b>	<b>1,800</b>
<b>4"</b>	<b>120</b>	<b>3,600</b>
<b>6"</b>	<b>400</b>	<b>12,000</b>

---

**Table C**

**Minimum Size and Slope of Sewer Mains\***

---

<b>Number of Spaces</b>	<b>Sewer Inside Diameter Inches</b>	<b>Minimum Slope per Foot</b>
<b>1-125</b>	<b>6</b>	<b>1/8"</b>
<b>more than 125</b>	<b>8</b>	<b>1/8"</b>

---

\*Exclusive of laterals serving individual mobile homes.

**Table D**

**Demand Factors for Feeder and Service Entrance Conductors**

---

<b>Number of Mobile Home Lots</b>	<b>Demand Factor (percent)</b>
<b>1</b>	<b>100</b>
<b>2</b>	<b>55</b>
<b>3</b>	<b>44</b>
<b>4</b>	<b>39</b>
<b>5</b>	<b>33</b>
<b>6</b>	<b>29</b>
<b>7-9</b>	<b>28</b>
<b>10-12</b>	<b>27</b>
<b>13-15</b>	<b>26</b>
<b>16-21</b>	<b>25</b>
<b>22-40</b>	<b>24</b>
<b>41-60</b>	<b>23</b>
<b>61 and over</b>	<b>22</b>

The demand factor for a given number of lots shall apply to all lots indicated.

Example: 20 lots calculated at 25 percent of 16,000 watts results in a permissible demand of 4,000 watts per lot or a total of 80,000 watts for 20 lots.

**ILLUSTRATION A**  
**WATER SERVICE CONNECTION**

**ILLUSTRATION B**

**SEWER SERVICE CONNECTION**